

CONPUTER GRAPHICS CHANGE RESTRICTED

NO MANGAL CHANGES

100% PRODUCTION LEAK TEST TO BE CONDUCTED AS FOLLOWS
THE VALVE SHALL PERMIT ZERO LEAKAGE (NO BUBBLES AT PORT B AND
ULTRASONIC JOINT) WHEN PORT A IS PRESSURIZED TO 3 PSI AND THE PART IS IMMERSED IN WATER FOR 3 SECONDS

VALVE SPECIFICATIONS

- 1) THE VALVE SHALL OPEN AND FLOW WHEN THE DIFFERENTIAL ACROSS THE VALVE IS 3.5 Kpa OR LESS
- 2) WHEN AIR FLOW THROUGH VALVE 1S 3000 CC/MIN THE DIFFERENTIAL ACROSS THE VALVE IS NOT TO EXCEED 1.0 Kpa
- 3) WITH A VOLUME OF 1 CU IN AT PORT B AT 10.0 IN MERCURY VACUUM AND ATMOSPHERIC PRESSURE AT PORT A THE VALVE SHALL PREVENT LOSS OF VACUUM AT ANY RATE GREATER THAN 3 IN MERCURY PER 15 MIN INTERVAL
- 4) IN GENERAL VALVE SHALL OPERATE SATISFACTORILY AND WITHOUT MALFUNCTION BETWEEN 121'C AND -40'C
- 5) WELD JOINT MUST WITHSTAND 20 LB PERPENDICULAR LOAD WITHOUT SEPARATION OR LEAKAGE BEYOND THAT SPECIFIED IN TEST *2 TEST CONDUCTED PER MPC PROCEDURE QP-11
- 6) CONTINUOUS MAX PRESSURE 50 PSI AT PORT A

